

Report for:

Mr. Brian Poplarchick
LaBella Associates, D.P.C
1000 Dunham Drive, Suite B
Dunmore, PA 18512

Regarding: Project: ESASD; ESASD - Lehman Int + E Stroudsburg H.S. North
EML ID: 2339147

Approved by:

Dates of Analysis:
Spore trap analysis: 01-23-2020



Technical Manager
Ariunaa Jalsrai

Service SOPs: Spore trap analysis (EM-MY-S-1038)
AIHA-LAP, LLC accredited service, Lab ID #103005

All samples were received in acceptable condition unless noted in the Report Comments portion in the body of the report. Due to the nature of the analyses performed, field blank correction of results is not applied. The results relate only to the samples as received. Sample air volume is supplied by the client.

Eurofins EMLab P&K ("the Company") shall have no liability to the client or the client's customer with respect to decisions or recommendations made, actions taken or courses of conduct implemented by either the client or the client's customer as a result of or based upon the Test Results. In no event shall the Company be liable to the client with respect to the Test Results except for the Company's own willful misconduct or gross negligence nor shall the Company be liable for incidental or consequential damages or lost profits or revenues to the fullest extent such liability may be disclaimed by law, even if the Company has been advised of the possibility of such damages, lost profits or lost revenues. In no event shall the Company's liability with respect to the Test Results exceed the amount paid to the Company by the client therefor.

Eurofins EMLab P&K's LabServe® reporting system includes automated fail-safes to ensure that all AIHA-LAP, LLC quality requirements are met and notifications are added to reports when any quality steps remain pending.

Client: LaBella Associates, D.P.C

C/O: Mr. Brian Poplarchick

Re: ESASD; ESASD - Lehman Int + E Stroudsburg

H.S. North

Date of Sampling: 01-21-2020

Date of Receipt: 01-22-2020

Date of Report: 02-26-2020

SPORE TRAP REPORT: NON-VIABLE METHODOLOGY

Location:	001: Lehman Int. Rm. 123B			002: Lehman Int. Rm. 120 Music Rm		
Comments (see below)	None			None		
Lab ID-Version‡:	11136757-1			11136758-1		
Analysis Date:	01/23/2020			01/23/2020		
	raw ct.	% read	spores/m3	raw ct.	% read	spores/m3
Ascospores						
Basidiospores	1	25	53			
Chaetomium						
Cladosporium						
Curvularia						
Epicoccum						
Fusarium						
Myrothecium						
Nigrospora						
Other colorless						
Penicillium/Aspergillus types†						
Pithomyces						
Rusts						
Smuts, Periconia, Myxomycetes				1	100	13
Stachybotrys						
Stemphylium						
Torula						
Ulocladium						
Zygomycetes						
Background debris (1-4+)††	1+			1+		
Hyphal fragments/m3	13			< 13		
Pollen/m3	< 13			< 13		
Skin cells (1-4+)	1+			1+		
Sample volume (liters)	75			75		
§ TOTAL SPORES/m3			53			13

Comments:

Spore types listed without a count or data entry were not detected during the course of the analysis for the respective sample, indicating a raw count of <1 spore.

† The spores of *Aspergillus* and *Penicillium* (and others such as *Acremonium*, *Paecilomyces*) are small and round with very few distinguishing characteristics. They cannot be differentiated by non-viable sampling methods. Also, some species with very small spores are easily missed, and may be undercounted.

†† Background debris indicates the amount of non-biological particulate matter present on the trace (dust in the air) and the resulting visibility for the analyst. It is rated from 1+ (low) to 4+ (high). Counts from areas with 4+ background debris should be regarded as minimal counts and may be higher than reported. It is important to account for samples volumes when evaluating dust levels.

The analytical sensitivity is the spores/m³ divided by the raw count, expressed in spores/m³. The limit of detection is the analytical sensitivity (in spores/m³) multiplied by the sample volume (in liters) divided by 1000 liters.

For more information regarding analytical sensitivity, please contact QA by calling the laboratory.

‡ A "Version" indicated by -"x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

§ Total Spores/m³ has been rounded to two significant figures to reflect analytical precision.

Client: LaBella Associates, D.P.C

C/O: Mr. Brian Poplarchick

Re: ESASD; ESASD - Lehman Int + E Stroudsburg

H.S. North

Date of Sampling: 01-21-2020

Date of Receipt: 01-22-2020

Date of Report: 02-26-2020

SPORE TRAP REPORT: NON-VIABLE METHODOLOGY

Location:	003: Lehman Int. Rm. 111			004: Lehman Int. Rm. 100 Health		
Comments (see below)	A			A		
Lab ID-Version‡:	11136759-1			11136760-1		
Analysis Date:	01/23/2020			01/23/2020		
	raw ct.	% read	spores/m3	raw ct.	% read	spores/m3
Ascospores						
Basidiospores						
Chaetomium						
Cladosporium						
Curvularia						
Epicoccum						
Fusarium						
Myrothecium						
Nigrospora						
Other colorless						
Penicillium/Aspergillus types†						
Pithomyces						
Rusts						
Smuts, Periconia, Myxomycetes						
Stachybotrys						
Stemphylium						
Torula						
Ulocladium						
Zygomycetes						
Background debris (1-4+)††	2+			1+		
Hyphal fragments/m3	< 13			< 13		
Pollen/m3	< 13			< 13		
Skin cells (1-4+)	1+			1+		
Sample volume (liters)	75			75		
§ TOTAL SPORES/m3			< 13			< 13

Comments: A) No spores detected.

Spore types listed without a count or data entry were not detected during the course of the analysis for the respective sample, indicating a raw count of <1 spore.

† The spores of *Aspergillus* and *Penicillium* (and others such as *Acremonium*, *Paecilomyces*) are small and round with very few distinguishing characteristics. They cannot be differentiated by non-viable sampling methods. Also, some species with very small spores are easily missed, and may be undercounted.

†† Background debris indicates the amount of non-biological particulate matter present on the trace (dust in the air) and the resulting visibility for the analyst. It is rated from 1+ (low) to 4+ (high). Counts from areas with 4+ background debris should be regarded as minimal counts and may be higher than reported. It is important to account for samples volumes when evaluating dust levels.

The analytical sensitivity is the spores/m³ divided by the raw count, expressed in spores/m³. The limit of detection is the analytical sensitivity (in spores/m³) multiplied by the sample volume (in liters) divided by 1000 liters.

For more information regarding analytical sensitivity, please contact QA by calling the laboratory.

‡ A "Version" indicated by -"x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

§ Total Spores/m³ has been rounded to two significant figures to reflect analytical precision.

Client: LaBella Associates, D.P.C

C/O: Mr. Brian Poplarchick

Re: ESASD; ESASD - Lehman Int + E Stroudsburg

H.S. North

Date of Sampling: 01-21-2020

Date of Receipt: 01-22-2020

Date of Report: 02-26-2020

SPORE TRAP REPORT: NON-VIABLE METHODOLOGY

Location:	005: Lehman Int. Rm. 202			006: Lehman Int. Rm. 207		
Comments (see below)	None			None		
Lab ID-Version‡:	11136761-1			11136762-1		
Analysis Date:	01/23/2020			01/23/2020		
	raw ct.	% read	spores/m3	raw ct.	% read	spores/m3
Ascospores						
Basidiospores						
Chaetomium						
Cladosporium						
Curvularia						
Epicoccum						
Fusarium						
Myrothecium						
Nigrospora						
Other colorless						
Penicillium/Aspergillus types†						
Pithomyces						
Rusts	1	100	13			
Smuts, Periconia, Myxomycetes				1	100	13
Stachybotrys						
Stemphylium						
Torula						
Ulocladium						
Zygomycetes						
Background debris (1-4+)††	2+			2+		
Hyphal fragments/m3	< 13			< 13		
Pollen/m3	< 13			< 13		
Skin cells (1-4+)	1+			2+		
Sample volume (liters)	75			75		
§ TOTAL SPORES/m3			13			13

Comments:

Spore types listed without a count or data entry were not detected during the course of the analysis for the respective sample, indicating a raw count of <1 spore.

† The spores of *Aspergillus* and *Penicillium* (and others such as *Acremonium*, *Paecilomyces*) are small and round with very few distinguishing characteristics. They cannot be differentiated by non-viable sampling methods. Also, some species with very small spores are easily missed, and may be undercounted.

†† Background debris indicates the amount of non-biological particulate matter present on the trace (dust in the air) and the resulting visibility for the analyst. It is rated from 1+ (low) to 4+ (high). Counts from areas with 4+ background debris should be regarded as minimal counts and may be higher than reported. It is important to account for samples volumes when evaluating dust levels.

The analytical sensitivity is the spores/m³ divided by the raw count, expressed in spores/m³. The limit of detection is the analytical sensitivity (in spores/m³) multiplied by the sample volume (in liters) divided by 1000 liters.

For more information regarding analytical sensitivity, please contact QA by calling the laboratory.

‡ A "Version" indicated by -"x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

§ Total Spores/m³ has been rounded to two significant figures to reflect analytical precision.

Client: LaBella Associates, D.P.C

C/O: Mr. Brian Poplarchick

Re: ESASD; ESASD - Lehman Int + E Stroudsburg

H.S. North

Date of Sampling: 01-21-2020

Date of Receipt: 01-22-2020

Date of Report: 02-26-2020

SPORE TRAP REPORT: NON-VIABLE METHODOLOGY

Location:	007: Lehman Int. Rm. 211			008: Lehman Int. Seminar 2B		
Comments (see below)	None			A		
Lab ID-Version‡:	11136763-1			11136764-1		
Analysis Date:	01/23/2020			01/23/2020		
	raw ct.	% read	spores/m3	raw ct.	% read	spores/m3
Ascospores						
Basidiospores	1	25	53			
Chaetomium						
Cladosporium						
Curvularia						
Epicoccum						
Fusarium						
Myrothecium						
Nigrospora						
Other colorless						
Penicillium/Aspergillus types†						
Pithomyces						
Rusts						
Smuts, Periconia, Myxomycetes						
Stachybotrys						
Stemphylium						
Torula						
Ulocladium						
Zygomycetes						
Background debris (1-4+)††	2+			2+		
Hyphal fragments/m3	< 13			< 13		
Pollen/m3	< 13			< 13		
Skin cells (1-4+)	1+			1+		
Sample volume (liters)	75			75		
§ TOTAL SPORES/m3			53			< 13

Comments: A) No spores detected.

Spore types listed without a count or data entry were not detected during the course of the analysis for the respective sample, indicating a raw count of <1 spore.

† The spores of *Aspergillus* and *Penicillium* (and others such as *Acremonium*, *Paecilomyces*) are small and round with very few distinguishing characteristics. They cannot be differentiated by non-viable sampling methods. Also, some species with very small spores are easily missed, and may be undercounted.

†† Background debris indicates the amount of non-biological particulate matter present on the trace (dust in the air) and the resulting visibility for the analyst. It is rated from 1+ (low) to 4+ (high). Counts from areas with 4+ background debris should be regarded as minimal counts and may be higher than reported. It is important to account for samples volumes when evaluating dust levels.

The analytical sensitivity is the spores/m³ divided by the raw count, expressed in spores/m³. The limit of detection is the analytical sensitivity (in spores/m³) multiplied by the sample volume (in liters) divided by 1000 liters.

For more information regarding analytical sensitivity, please contact QA by calling the laboratory.

‡ A "Version" indicated by -"x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

§ Total Spores/m³ has been rounded to two significant figures to reflect analytical precision.

Client: LaBella Associates, D.P.C

C/O: Mr. Brian Poplarchick

Re: ESASD; ESASD - Lehman Int + E Stroudsburg

H.S. North

Date of Sampling: 01-21-2020

Date of Receipt: 01-22-2020

Date of Report: 02-26-2020

SPORE TRAP REPORT: NON-VIABLE METHODOLOGY

Location:	009: Lehman Int. Rm. 305			010: Lehman Int. Rm. 312		
Comments (see below)	None			A		
Lab ID-Version‡:	11136765-1			11136766-1		
Analysis Date:	01/23/2020			01/23/2020		
	raw ct.	% read	spores/m3	raw ct.	% read	spores/m3
Ascospores						
Basidiospores						
Chaetomium						
Cladosporium						
Curvularia						
Epicoccum						
Fusarium						
Myrothecium						
Nigrospora						
Other colorless						
Penicillium/Aspergillus types†						
Pithomyces						
Rusts						
Smuts, Periconia, Myxomycetes	2	100	27			
Stachybotrys						
Stemphylium						
Torula						
Ulocladium						
Zygomycetes						
Background debris (1-4+)††	2+			1+		
Hyphal fragments/m3	13			< 13		
Pollen/m3	< 13			< 13		
Skin cells (1-4+)	1+			1+		
Sample volume (liters)	75			75		
§ TOTAL SPORES/m3			27			< 13

Comments: A) No spores detected.

Spore types listed without a count or data entry were not detected during the course of the analysis for the respective sample, indicating a raw count of <1 spore.

† The spores of *Aspergillus* and *Penicillium* (and others such as *Acremonium*, *Paecilomyces*) are small and round with very few distinguishing characteristics. They cannot be differentiated by non-viable sampling methods. Also, some species with very small spores are easily missed, and may be undercounted.

†† Background debris indicates the amount of non-biological particulate matter present on the trace (dust in the air) and the resulting visibility for the analyst. It is rated from 1+ (low) to 4+ (high). Counts from areas with 4+ background debris should be regarded as minimal counts and may be higher than reported. It is important to account for samples volumes when evaluating dust levels.

The analytical sensitivity is the spores/m³ divided by the raw count, expressed in spores/m³. The limit of detection is the analytical sensitivity (in spores/m³) multiplied by the sample volume (in liters) divided by 1000 liters.

For more information regarding analytical sensitivity, please contact QA by calling the laboratory.

‡ A "Version" indicated by -"x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

§ Total Spores/m³ has been rounded to two significant figures to reflect analytical precision.

Client: LaBella Associates, D.P.C
 C/O: Mr. Brian Poplarchick
 Re: ESASD; ESASD - Lehman Int + E Stroudsburg
 H.S. North

Date of Sampling: 01-21-2020
 Date of Receipt: 01-22-2020
 Date of Report: 02-26-2020

SPORE TRAP REPORT: NON-VIABLE METHODOLOGY

Location:	025: Lehman Intermediate Main Office			026: Exterior		
Comments (see below)	None			None		
Lab ID-Version‡:	11136781-1			11136782-1		
Analysis Date:	01/23/2020			01/23/2020		
	raw ct.	% read	spores/m3	raw ct.	% read	spores/m3
Ascospores						
Basidiospores	1	25	53	2	25	110
Chaetomium						
Cladosporium						
Curvularia						
Epicoccum						
Fusarium						
Myrothecium						
Nigrospora						
Other colorless						
Penicillium/Aspergillus types†						
Pithomyces						
Rusts						
Smuts, Periconia, Myxomycetes						
Stachybotrys						
Stemphylium						
Torula						
Ulocladium						
Zygomycetes						
Background debris (1-4+)††	2+			1+		
Hyphal fragments/m3	< 13			13		
Pollen/m3	< 13			< 13		
Skin cells (1-4+)	1+			< 1+		
Sample volume (liters)	75			75		
§ TOTAL SPORES/m3			53			110

Comments:

Spore types listed without a count or data entry were not detected during the course of the analysis for the respective sample, indicating a raw count of <1 spore.

† The spores of *Aspergillus* and *Penicillium* (and others such as *Acremonium*, *Paecilomyces*) are small and round with very few distinguishing characteristics. They cannot be differentiated by non-viable sampling methods. Also, some species with very small spores are easily missed, and may be undercounted.

†† Background debris indicates the amount of non-biological particulate matter present on the trace (dust in the air) and the resulting visibility for the analyst. It is rated from 1+ (low) to 4+ (high). Counts from areas with 4+ background debris should be regarded as minimal counts and may be higher than reported. It is important to account for samples volumes when evaluating dust levels.

The analytical sensitivity is the spores/m³ divided by the raw count, expressed in spores/m³. The limit of detection is the analytical sensitivity (in spores/m³) multiplied by the sample volume (in liters) divided by 1000 liters.

For more information regarding analytical sensitivity, please contact QA by calling the laboratory.

‡ A "Version" indicated by -"x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

§ Total Spores/m³ has been rounded to two significant figures to reflect analytical precision.

Report for:

Mr. Brian Poplarchick
LaBella Associates, D.P.C
1000 Dunham Drive, Suite B
Dunmore, PA 18512

Regarding: Project: ESASD; ESASD - Lehman Int + E Stroudsburg H.S. North
EML ID: 2339147

Approved by:

Dates of Analysis:
Spore trap analysis: 01-23-2020



Technical Manager
Ariunaa Jalsrai

Service SOPs: Spore trap analysis (EM-MY-S-1038)
AIHA-LAP, LLC accredited service, Lab ID #103005

All samples were received in acceptable condition unless noted in the Report Comments portion in the body of the report. Due to the nature of the analyses performed, field blank correction of results is not applied. The results relate only to the samples as received. Sample air volume is supplied by the client.

Eurofins EMLab P&K ("the Company") shall have no liability to the client or the client's customer with respect to decisions or recommendations made, actions taken or courses of conduct implemented by either the client or the client's customer as a result of or based upon the Test Results. In no event shall the Company be liable to the client with respect to the Test Results except for the Company's own willful misconduct or gross negligence nor shall the Company be liable for incidental or consequential damages or lost profits or revenues to the fullest extent such liability may be disclaimed by law, even if the Company has been advised of the possibility of such damages, lost profits or lost revenues. In no event shall the Company's liability with respect to the Test Results exceed the amount paid to the Company by the client therefor.

Eurofins EMLab P&K's LabServe® reporting system includes automated fail-safes to ensure that all AIHA-LAP, LLC quality requirements are met and notifications are added to reports when any quality steps remain pending.

Client: LaBella Associates, D.P.C

C/O: Mr. Brian Poplarchick

Re: ESASD; ESASD - Lehman Int + E Stroudsburg

H.S. North

Date of Sampling: 01-21-2020

Date of Receipt: 01-22-2020

Date of Report: 02-26-2020

SPORE TRAP REPORT: NON-VIABLE METHODOLOGY

Location:	011: E. Stroudsburg High School North Rm. 109 Art/Photo			012: E. Stroudsburg High School North Rm. 108		
Comments (see below)	None			A		
Lab ID-Version‡:	11136767-1			11136768-1		
Analysis Date:	01/23/2020			01/23/2020		
	raw ct.	% read	spores/m3	raw ct.	% read	spores/m3
Ascospores						
Basidiospores						
Chaetomium						
Cladosporium						
Curvularia						
Epicoccum						
Fusarium						
Myrothecium						
Nigrospora						
Other colorless						
Penicillium/Aspergillus types†						
Pithomyces	1	100	13			
Rusts						
Smuts, Periconia, Myxomycetes						
Stachybotrys						
Stemphylium						
Torula						
Ulocladium						
Background debris (1-4+)††	1+			1+		
Hyphal fragments/m3	13			< 13		
Pollen/m3	< 13			< 13		
Skin cells (1-4+)	1+			1+		
Sample volume (liters)	75			75		
§ TOTAL SPORES/m3			13			< 13

Comments: A) No spores detected.

Spore types listed without a count or data entry were not detected during the course of the analysis for the respective sample, indicating a raw count of <1 spore.

† The spores of *Aspergillus* and *Penicillium* (and others such as *Acremonium*, *Paecilomyces*) are small and round with very few distinguishing characteristics. They cannot be differentiated by non-viable sampling methods. Also, some species with very small spores are easily missed, and may be undercounted.

†† Background debris indicates the amount of non-biological particulate matter present on the trace (dust in the air) and the resulting visibility for the analyst. It is rated from 1+ (low) to 4+ (high). Counts from areas with 4+ background debris should be regarded as minimal counts and may be higher than reported. It is important to account for samples volumes when evaluating dust levels.

The analytical sensitivity is the spores/m³ divided by the raw count, expressed in spores/m³. The limit of detection is the analytical sensitivity (in spores/m³) multiplied by the sample volume (in liters) divided by 1000 liters.

For more information regarding analytical sensitivity, please contact QA by calling the laboratory.

‡ A "Version" indicated by -"x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

§ Total Spores/m³ has been rounded to two significant figures to reflect analytical precision.

Client: LaBella Associates, D.P.C

C/O: Mr. Brian Poplarchick

Re: ESASD; ESASD - Lehman Int + E Stroudsburg

H.S. North

Date of Sampling: 01-21-2020

Date of Receipt: 01-22-2020

Date of Report: 02-26-2020

SPORE TRAP REPORT: NON-VIABLE METHODOLOGY

Location:	013: E. Stroudsburg High School North Rm. 117 Chemistry			014: E. Stroudsburg High School North Rm. 120		
Comments (see below)	None			None		
Lab ID-Version‡:	11136769-1			11136770-1		
Analysis Date:	01/23/2020			01/23/2020		
	raw ct.	% read	spores/m ³	raw ct.	% read	spores/m ³
Ascospores						
Basidiospores						
Chaetomium						
Cladosporium						
Curvularia						
Epicoccum						
Fusarium						
Myrothecium						
Nigrospora						
Other colorless						
Penicillium/Aspergillus types†	5	25	270	1	25	53
Pithomyces						
Rusts						
Smuts, Periconia, Myxomycetes				1	100	13
Stachybotrys						
Stemphylium						
Torula						
Ulocladium						
Background debris (1-4+)††	2+			1+		
Hyphal fragments/m ³	< 13			< 13		
Pollen/m ³	< 13			< 13		
Skin cells (1-4+)	1+			1+		
Sample volume (liters)	75			75		
§ TOTAL SPORES/m³			270			67

Comments:

Spore types listed without a count or data entry were not detected during the course of the analysis for the respective sample, indicating a raw count of <1 spore.

† The spores of *Aspergillus* and *Penicillium* (and others such as *Acremonium*, *Paecilomyces*) are small and round with very few distinguishing characteristics. They cannot be differentiated by non-viable sampling methods. Also, some species with very small spores are easily missed, and may be undercounted.

†† Background debris indicates the amount of non-biological particulate matter present on the trace (dust in the air) and the resulting visibility for the analyst. It is rated from 1+ (low) to 4+ (high). Counts from areas with 4+ background debris should be regarded as minimal counts and may be higher than reported. It is important to account for samples volumes when evaluating dust levels.

The analytical sensitivity is the spores/m³ divided by the raw count, expressed in spores/m³. The limit of detection is the analytical sensitivity (in spores/m³) multiplied by the sample volume (in liters) divided by 1000 liters.

For more information regarding analytical sensitivity, please contact QA by calling the laboratory.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

§ Total Spores/m³ has been rounded to two significant figures to reflect analytical precision.

Client: LaBella Associates, D.P.C
 C/O: Mr. Brian Poplarchick
 Re: ESASD; ESASD - Lehman Int + E Stroudsburg
 H.S. North

Date of Sampling: 01-21-2020
 Date of Receipt: 01-22-2020
 Date of Report: 02-26-2020

SPORE TRAP REPORT: NON-VIABLE METHODOLOGY

Location:	015: E. Stroudsburg High School North Rm. 127			016: E. Stroudsburg High School North Gymnasium		
Comments (see below)	None			A		
Lab ID-Version‡:	11136771-1			11136772-1		
Analysis Date:	01/23/2020			01/23/2020		
	raw ct.	% read	spores/m3	raw ct.	% read	spores/m3
Ascospores						
Basidiospores						
Chaetomium						
Cladosporium						
Curvularia						
Epicoccum						
Fusarium						
Myrothecium						
Nigrospora						
Other colorless						
Penicillium/Aspergillus types†						
Pithomyces						
Rusts						
Smuts, Periconia, Myxomycetes	2	100	27			
Stachybotrys						
Stemphylium						
Torula						
Ulocladium						
Background debris (1-4+)††	2+			< 1+		
Hyphal fragments/m3	< 13			< 13		
Pollen/m3	< 13			< 13		
Skin cells (1-4+)	1+			< 1+		
Sample volume (liters)	75			75		
§ TOTAL SPORES/m3			27			< 13

Comments: A) No spores detected.

Spore types listed without a count or data entry were not detected during the course of the analysis for the respective sample, indicating a raw count of <1 spore.

† The spores of *Aspergillus* and *Penicillium* (and others such as *Acremonium*, *Paecilomyces*) are small and round with very few distinguishing characteristics. They cannot be differentiated by non-viable sampling methods. Also, some species with very small spores are easily missed, and may be undercounted.

†† Background debris indicates the amount of non-biological particulate matter present on the trace (dust in the air) and the resulting visibility for the analyst. It is rated from 1+ (low) to 4+ (high). Counts from areas with 4+ background debris should be regarded as minimal counts and may be higher than reported. It is important to account for samples volumes when evaluating dust levels.

The analytical sensitivity is the spores/m³ divided by the raw count, expressed in spores/m³. The limit of detection is the analytical sensitivity (in spores/m³) multiplied by the sample volume (in liters) divided by 1000 liters.

For more information regarding analytical sensitivity, please contact QA by calling the laboratory.

‡ A "Version" indicated by -"x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

§ Total Spores/m³ has been rounded to two significant figures to reflect analytical precision.

Client: LaBella Associates, D.P.C

C/O: Mr. Brian Poplarchick

Re: ESASD; ESASD - Lehman Int + E Stroudsburg

H.S. North

Date of Sampling: 01-21-2020

Date of Receipt: 01-22-2020

Date of Report: 02-26-2020

SPORE TRAP REPORT: NON-VIABLE METHODOLOGY

Location:	017: E. Stroudsburg High School North Rm. 300			018: E. Stroudsburg High School North Rm. 308		
Comments (see below)	None			None		
Lab ID-Version‡:	11136773-1			11136774-1		
Analysis Date:	01/23/2020			01/23/2020		
	raw ct.	% read	spores/m3	raw ct.	% read	spores/m3
Ascospores						
Basidiospores	1	25	53			
Chaetomium						
Cladosporium				1	25	53
Curvularia						
Epicoccum						
Fusarium						
Myrothecium						
Nigrospora						
Other colorless				1	100	13
Penicillium/Aspergillus types†	1	25	53			
Pithomyces						
Rusts						
Smuts, Periconia, Myxomycetes						
Stachybotrys						
Stemphylium						
Torula						
Ulocladium						
Background debris (1-4+)††	2+			2+		
Hyphal fragments/m3	< 13			< 13		
Pollen/m3	< 13			< 13		
Skin cells (1-4+)	1+			1+		
Sample volume (liters)	75			75		
§ TOTAL SPORES/m3			110			67

Comments:

Spore types listed without a count or data entry were not detected during the course of the analysis for the respective sample, indicating a raw count of <1 spore.

† The spores of *Aspergillus* and *Penicillium* (and others such as *Acremonium*, *Paecilomyces*) are small and round with very few distinguishing characteristics. They cannot be differentiated by non-viable sampling methods. Also, some species with very small spores are easily missed, and may be undercounted.

†† Background debris indicates the amount of non-biological particulate matter present on the trace (dust in the air) and the resulting visibility for the analyst. It is rated from 1+ (low) to 4+ (high). Counts from areas with 4+ background debris should be regarded as minimal counts and may be higher than reported. It is important to account for samples volumes when evaluating dust levels.

The analytical sensitivity is the spores/m³ divided by the raw count, expressed in spores/m³. The limit of detection is the analytical sensitivity (in spores/m³) multiplied by the sample volume (in liters) divided by 1000 liters.

For more information regarding analytical sensitivity, please contact QA by calling the laboratory.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

§ Total Spores/m³ has been rounded to two significant figures to reflect analytical precision.

Client: LaBella Associates, D.P.C

C/O: Mr. Brian Poplarchick

Re: ESASD; ESASD - Lehman Int + E Stroudsburg

H.S. North

Date of Sampling: 01-21-2020

Date of Receipt: 01-22-2020

Date of Report: 02-26-2020

SPORE TRAP REPORT: NON-VIABLE METHODOLOGY

Location:	019: E. Stroudsburg High School North Rm. 226			020: E. Stroudsburg High School North Rm. 231		
Comments (see below)	A			A		
Lab ID-Version‡:	11136775-1			11136776-1		
Analysis Date:	01/23/2020			01/23/2020		
	raw ct.	% read	spores/m ³	raw ct.	% read	spores/m ³
Ascospores						
Basidiospores						
Chaetomium						
Cladosporium						
Curvularia						
Epicoccum						
Fusarium						
Myrothecium						
Nigrospora						
Other colorless						
Penicillium/Aspergillus types†						
Pithomyces						
Rusts						
Smuts, Periconia, Myxomycetes						
Stachybotrys						
Stemphylium						
Torula						
Ulocladium						
Background debris (1-4+)††	2+			2+		
Hyphal fragments/m ³	< 13			< 13		
Pollen/m ³	13			< 13		
Skin cells (1-4+)	1+			1+		
Sample volume (liters)	75			75		
§ TOTAL SPORES/m³			< 13			< 13

Comments: A) No spores detected.

Spore types listed without a count or data entry were not detected during the course of the analysis for the respective sample, indicating a raw count of <1 spore.

† The spores of *Aspergillus* and *Penicillium* (and others such as *Acremonium*, *Paecilomyces*) are small and round with very few distinguishing characteristics. They cannot be differentiated by non-viable sampling methods. Also, some species with very small spores are easily missed, and may be undercounted.

†† Background debris indicates the amount of non-biological particulate matter present on the trace (dust in the air) and the resulting visibility for the analyst. It is rated from 1+ (low) to 4+ (high). Counts from areas with 4+ background debris should be regarded as minimal counts and may be higher than reported. It is important to account for samples volumes when evaluating dust levels.

The analytical sensitivity is the spores/m³ divided by the raw count, expressed in spores/m³. The limit of detection is the analytical sensitivity (in spores/m³) multiplied by the sample volume (in liters) divided by 1000 liters.

For more information regarding analytical sensitivity, please contact QA by calling the laboratory.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

§ Total Spores/m³ has been rounded to two significant figures to reflect analytical precision.

Client: LaBella Associates, D.P.C
 C/O: Mr. Brian Poplarchick
 Re: ESASD; ESASD - Lehman Int + E Stroudsburg
 H.S. North

Date of Sampling: 01-21-2020
 Date of Receipt: 01-22-2020
 Date of Report: 02-26-2020

SPORE TRAP REPORT: NON-VIABLE METHODOLOGY

Location:	021: E. Stroudsburg High School North Rm. 216 Biology lab			022: E. Stroudsburg High School North Rm. 209		
Comments (see below)	None			None		
Lab ID-Version‡:	11136777-1			11136778-1		
Analysis Date:	01/23/2020			01/23/2020		
	raw ct.	% read	spores/m3	raw ct.	% read	spores/m3
Ascospores						
Basidiospores						
Chaetomium						
Cladosporium	1	25	53			
Curvularia						
Epicoccum	1	100	13			
Fusarium						
Myrothecium						
Nigrospora						
Other colorless						
Penicillium/Aspergillus types†				1	25	53
Pithomyces						
Rusts						
Smuts, Periconia, Myxomycetes						
Stachybotrys						
Stemphylium						
Torula						
Ulocladium						
Background debris (1-4+)††	1+			1+		
Hyphal fragments/m3	< 13			< 13		
Pollen/m3	< 13			< 13		
Skin cells (1-4+)	1+			1+		
Sample volume (liters)	75			75		
§ TOTAL SPORES/m3			67			53

Comments:

Spore types listed without a count or data entry were not detected during the course of the analysis for the respective sample, indicating a raw count of <1 spore.

† The spores of *Aspergillus* and *Penicillium* (and others such as *Acremonium*, *Paecilomyces*) are small and round with very few distinguishing characteristics. They cannot be differentiated by non-viable sampling methods. Also, some species with very small spores are easily missed, and may be undercounted.

†† Background debris indicates the amount of non-biological particulate matter present on the trace (dust in the air) and the resulting visibility for the analyst. It is rated from 1+ (low) to 4+ (high). Counts from areas with 4+ background debris should be regarded as minimal counts and may be higher than reported. It is important to account for samples volumes when evaluating dust levels.

The analytical sensitivity is the spores/m³ divided by the raw count, expressed in spores/m³. The limit of detection is the analytical sensitivity (in spores/m³) multiplied by the sample volume (in liters) divided by 1000 liters.

For more information regarding analytical sensitivity, please contact QA by calling the laboratory.

‡ A "Version" indicated by -"x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

§ Total Spores/m³ has been rounded to two significant figures to reflect analytical precision.

Client: LaBella Associates, D.P.C
C/O: Mr. Brian Poplarchick
Re: ESASD; ESASD - Lehman Int + E Stroudsburg
H.S. North

Date of Sampling: 01-21-2020
Date of Receipt: 01-22-2020
Date of Report: 02-26-2020

SPORE TRAP REPORT: NON-VIABLE METHODOLOGY

Location:	023: E. Stroudsburg High School North Rm. 202			024: E. Stroudsburg High School North Rm. 200 Faculty Lounge			026: Exterior		
Comments (see below)	A			None			None		
Lab ID-Version‡:	11136779-1			11136780-1			11136782-1		
Analysis Date:	01/23/2020			01/23/2020			01/23/2020		
	raw ct.	% read	spores/m3	raw ct.	% read	spores/m3	raw ct.	% read	spores/m3
Ascospores									
Basidiospores				1	25	53	2	25	110
Chaetomium									
Cladosporium				1	25	53			
Epicoccum									
Fusarium									
Myrothecium									
Nigrospora									
Other colorless									
Penicillium/Aspergillus types†				1	25	53			
Pithomyces									
Rusts									
Smuts, Periconia, Myxomycetes									
Stachybotrys									
Stemphylium									
Torula									
Ulocladium									
Background debris (1-4+)††	1+			1+			1+		
Hyphal fragments/m3	13			< 13			13		
Pollen/m3	< 13			< 13			< 13		
Skin cells (1-4+)	1+			1+			< 1+		
Sample volume (liters)	75			75			75		
§ TOTAL SPORES/m3			< 13			160			110

Comments: A) No spores detected.

Spore types listed without a count or data entry were not detected during the course of the analysis for the respective sample, indicating a raw count of <1 spore.

† The spores of *Aspergillus* and *Penicillium* (and others such as *Acremonium*, *Paecilomyces*) are small and round with very few distinguishing characteristics. They cannot be differentiated by non-viable sampling methods. Also, some species with very small spores are easily missed, and may be undercounted.

†† Background debris indicates the amount of non-biological particulate matter present on the trace (dust in the air) and the resulting visibility for the analyst. It is rated from 1+ (low) to 4+ (high). Counts from areas with 4+ background debris should be regarded as minimal counts and may be higher than reported. It is important to account for samples volumes when evaluating dust levels.

The analytical sensitivity is the spores/m³ divided by the raw count, expressed in spores/m³. The limit of detection is the analytical sensitivity (in spores/m³) multiplied by the sample volume (in liters) divided by 1000 liters.

For more information regarding analytical sensitivity, please contact QA by calling the laboratory.

‡ A "Version" indicated by -"x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

§ Total Spores/m³ has been rounded to two significant figures to reflect analytical precision.